



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA203165

Date of Issue: 28 March 2022

Regulatory Definition: Non-Declared

Product Description: Air-conditioning unit for cabinet

| Additional Models | Trade Name | Rating/Marking |
|-------------------|---------------|---|
| IP-ACIWM035.002 | IP Enclosures | 230Vac 50/60Hz Max 320W R134a/300g, Max Pressure: 2400kPA Class I, IP34 (External side), IP54 (Internal side) |
| IP-ACIWM035.003 | IP Enclosures | 230Vac 50/60Hz Max 320W R134a/300g, Max Pressure: 2400kPA Class I, IP34 (External side), IP54 (Internal side) |
| IP-ACOWM035.002 | IP Enclosures | 230Vac 50/60Hz Max 320W R134a/300g, Max Pressure: 2400kPA Class I, IP34 (External side), IP54 (Internal side) |
| IP-ACOWM035.003 | IP Enclosures | 230Vac 50/60Hz Max 320W R134a/300g, Max Pressure: 2400kPA Class I, IP34 (External side), IP54 (Internal side) |
| IP-ACIWM085.002 | IP Enclosures | 230Vac 50/60Hz Max 600W R134a/390g, Max Pressure: 2400kPA Class I, IP34 (External side), IP54 (Internal side) |
| IP-ACIWM085.003 | IP Enclosures | 230Vac 50/60Hz Max 600W R134a/390g, Max Pressure: 2400kPA Class I, IP34 (External side), IP54 (Internal side) |
| IP-ACOWM085.002 | IP Enclosures | 230Vac 50/60Hz Max 600W R134a/390g, Max Pressure: 2400kPA Class I, IP34 (External side), IP54 (Internal side) |
| IP-ACOWM085.003 | IP Enclosures | 230Vac 50/60Hz Max 600W R134a/390g, Max Pressure: 2400kPA Class I, IP34 (External side), IP54 (Internal side) |

For and on Behalf of
SAA Approvals Pty Ltd

SAA certifies the product nominated in this certificate complies with standard/s listed above.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



Issued: 28-03-22 203165/5