



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA203165

**Certificate Holder:** Tro Pacific Holdings Pty Ltd  
19 27 Fred Chaplin Circuit  
Bells Creek QLD 4551  
Australia

**Regulatory Definition:** Non-Declared  
**Product Description:** Air-conditioning unit for cabinet  
**Trade Name/ s:** IP Enclosures  
**Model No.:** IP-ACIWM035  
**Rating/ Marking/ s:** 230Vac, 50/60Hz, Max.320W  
R134a/300g, Max. Pressure: 2400kPA  
Class I, IP34 (External side), IP54 (Internal side)

**Standard/ s:** AS/NZS 60335.2.40:2019  
AS/NZS 60335.1:2020

**Condition/ s:** Nil

**Approval Marks:** SAA203165

**Initial Issue Date:** 1 April 2021

**Expiry Date:** 1 April 2026

For and on Behalf of  
SAA Approvals Pty Ltd

SAA certifies the product nominated in this certificate  
complies with standard/s listed above.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)



Issued: 01-04-21 203165/1